



EC Declaration of Conformity

Name: Selec Controls Pvt. Ltd.
Address: EL-27/1, Electronic zone, TTC Industrial Area,
Mahape, Navi Mumbai, India-400710.

Declare under sole responsibility that the following described products

Product Name: **Phase Sequence Relay**

Model Type: **600PSR-CE**

Year in which CE Mark was affixed: **2011**

Year in which CE Mark update : **2017(for IEC61326-1 : 2013)**

To which this declaration relates is in conformity with the following standards:

IEC 61326-1	2013	EMC
IEC 61010-1	2010	Safety requirements

Following the provision of EU Directives

2014/35/EU : Low voltage directive

2014/30/EU : EMC directive.

The Technical Construction file is maintained at Selec Controls Pvt Ltd, Navi Mumbai, India.

Selec Controls Pvt Ltd, Mumbai India

(Place of issue)

Ms. Priti Parekh (Sr. Design Engineer)

(Name and Designation of the Authorized Person)

(20 Dec 2011)

(Date of issue)

(10 APR 2017)

(Date of updated issue)

P. J. Parekh

(Signature of Authorized Person)



Sr No	Test Conducted	Trip value (V)	Observed Trip value during test (V)	Observed Trip value after test (V)
1	Over voltage pot position at 25%	519	515.4	513.4
2	Over voltage pot position at 10%	456	454	452.3
3	Under voltage pot position at 25%	311	312.4	311.8
4	Under voltage pot position at 10%	373.5	376.7	374

Test Observation:

Sr.No.	Temperature	Duration	Observation	Remark
1	70 °C max. rated ambient temperature \pm 2°C (Operational)	4 hour	No functional degradation	Pass

General remarks: NA

Test Conclusion: No functional degradation observed during and after the test. ^{LED.} (only indication checked)

Pranav
22/6/17

Tested By: Pranav
Testing Engineer

Accuracy within limit

MB
22/6/17

Supervised By: Mahesh V.
Product Engineer

Priti
22/6/17

Approved By: Priti Ma'am.
Senior Engineer

