## Standards compliance

| Category | Reference standards | Testing level |
|---|---|---|
| Electrostatic discharge | IEC 61000-4-2 | Level-3 |
| Electrical fast transient / Brust | IEC 61000-4-4 | Level-3 |
| Electromagnetic field | IEC 61000-4-3 | Level-3 |
| Surge | IEC 61000-4-5 | Level-3 |
| Conducted RF | IEC 61000-4-6 | Level-2 |
| Rated power frequency | IEC 61000-4-8 | Level-4 |
| Voltage dip / Short interruptions | IEC 61000-4-11 | Level-3 |
| Conducted emissions | CISPR-11 | Class-A |
| Rated emissions | CISPR-11 | Class-A |
| Safety | IEC 61010-1 | |

## Timing diagram

**ON Delay**




T= Set time

**Interval**




T= Set time

## Ordering information

| | | |
|---|---|---|
| **800XU** | 20 to 240V AC<br>12 to 240V DC | — |