



EU Type Examination Certificate Number: 0120/SGS0411

Selec Controls Pvt Limited

EL-27/1, Electronic Zone, TTC Industrial Area, MIDC, Mahape, 400 710, Maharashtra, India

Instrument Identification:

MFM384-C-CU-MID

Active Import/Export (kWh), Transformer Operated. Electricity Meter with Auxiliary Power Supply

Instrument Traceable Number 0120/SGS0411

has been assessed and certified as meeting the requirements of

EU Directive 2014/32/EU

on Measuring Instruments Annex II, Module B

It is certified that the manufacturer's technical design and specimen for the above instrument has been examined and, based on the evidence submitted; it is considered that the instrument conforms to the requirements of Annex V of EU Directive 2014/32/EU.

This certificate must be used in conjunction with a certificate covering the product verification as required in Annex II, Module D or Annex II, Module F

> This certificate is valid until 13th September 2026 Issue 2

Certification is based on report number(s) TCM 221/16 – 5392 EMA265549

Authorised Signature

HC.

SGS United Kingdom Limited, Notified Body 0120 Unit 202B Worle Parkway, Weston-super-Mare, BS22 6WA, UK t +44 (0)1934 522917 f +44 (0)1934 522137 www.sgs.com

Contact Address

SGS United Kingdom Limited, Units 12A & 12B, South Industrial Estate, Bowburn, Durham, DH6 5AD, UK t +44 (0)191 377 2000 f +44 (0)191 377 2020 www.sgs.com

SGS

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.

The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this Discost MB-002-Reposition contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights an Page floof 8 under the transaction documents.

SGSPAPER

19794719

